Heritage At Risk Register

Halnaker Windmill BOXGROVE

Asset Type: Grid Reference: Parish: Conservation Area: SDNP: Description: Priority: Reason for Risk: Registered: Last Assessed: Ownership: Current Status:	Listed Building - Grade II 491999, 109643 Boxgrove No Yes A prominent landmark. Built in 1740. Restored from a complete ruin in 1934. Brick shell with no internal workings. Red brick with blue headers, covered with a thin coating of burnt Sussex tiles. Octagonal cap of beehive shape with finial made of fiberglass on a wooden structure. E Historic building with original use redundant. 1993 27 March 2012 West Sussex County Council Three sweeps replaced 27 March 2012. Repointing of brickwork to upper levels being undertaken in lime mortar. Tile hanging cracking and failing throughout. Some tile and mortar fragments falling away from surface. Door missing. Continue to monitor.
Photograph 2012	

Priority

- A Immediate risk of further rapid deterioration or loss of fabric; no solution agreed.
- B Immediate risk of further rapid deterioration or loss of fabric; solution agreed but not yet implemented.
- **C** Slow decay; no solution agreed.
- D Slow decay; solution agreed but not yet implemented.
- E Under repair or in fair to good repair, but no user identified; or under threat of vacancy with no obvious new user. (Applicable only to buildings capable of beneficial use.)
- **F** Repair scheme in progress and (where applicable) end use or user identified; functionally redundant buildings with new use agreed but not yet implemented.